



# **Digital CO<sub>2</sub> Probe for Demanding Applications**

The E+E  $CO_2$  probe EE871 is designed for use in harsh, demanding OEM applications. A multiple point  $CO_2$  and temperature adjustment procedure leads to excellent  $CO_2$  measurement accuracy over the entire temperature working range, ideal for use in agriculture or outdoors. EE871 incorporates the dual wavelength NDIR  $CO_2$ sensor, which automatically compensates for ageing effects and is highly insensitive to pollution.

The IP65 enclosure and the replaceable PTFE filter offer excellent protection in harsh, polluted environment. The compact size, the M12 connector and the optional mounting flange allow for fast probe installation or replacement. With the optional radiation shield, EE871 can be also used outdoors.

The measured data range of up to 5 %  $CO_2$  (50,000 ppm) is available on E2 digital interface and up to 1 %  $CO_2$  (10.000 ppm) is available on Modbus RTU interface.



An optional kit facilitates easy configuration and adjustment of EE871. The measurement interval can be set according to the application requirements, by this the average current consumption can be reduced to 120  $\mu$ A for battery-operated devices.

### **Typical Applications**

Greenhouses and livestock barns Fruit and vegetable storage Hatchers and incubators Outdoor CO<sub>2</sub> monitoring Data loggers and handhelds Auto-calibration Outstanding long-term stability Temperature compensation Very low current consumption IP65 enclosure Modbus RTU or E2 interface

**Key Features** 

## **Technical Data**

#### Measured values

	Measuring principle Dual wavelength (non-dispersive infrared technology) NDIR			
	Measurement range	02000 ppm:	< ± (50 ppm + 2 % from the measured value)	
	Accuracy at 25 °C and	05000 ppm:	< ± (50 ppm + 3 % from the measured value)	
	1013 mbar <sup>1)</sup> (77 °F14,69 psi)	010,000 ppm:	< ± (100 ppm + 5 % from the measured value)	
		03 %: 05 %:	< $\pm$ (1,5 % from full scale + 2 % from the measured value)	
	Response time t <sub>90</sub> 105 s with measured data averaging (smooth output) 60 s without measured data averaging			
	Temperature dependency (-2045 °C) (-4113 °F)	02000 ppm: 05000 ppm: 010,000 ppm:	typ. $\pm$ (1 + CO <sub>2</sub> concentration [ppm] / 1000) ppm/°C	
		03 %: 05 %:	typ0,3 % from the measured value/°C	
	Measurement interval	adjustable from 15 s to 1 h (Factory setting: 15 s)		
Gene	eral			
	Digital interface	Modbus RTU or	E2 (details: www.epluse.com)	
	Supply voltage	4.75 - 7.5 VDC		

1) For averaging output







Current peak	max. 350 mA for 0.05 s	
Housing / Protection class	Plastic PC / Housing IP65	
Electrical connection	Connector M12 x 1	
Cable length E2 interface	max. 10 m (32.8 ft)	
Electromagnetic compatibility	EN61326-1	((
(Industrial enviroment)	EN61326-2-3	
Operating conditions	_4060 °C (-40140 °F) 0100 % RH (non-condensing) 85110 kF	<b>Da</b> (12,3315,95 psi)
Storage conditions	-4060 °C (-40140 °F) 0100 % RH (non-condensing) 70110 kF	<b>Da</b> (10,1515,95 psi)

2) The average current consumption depends on the measurement interval

## Connection .

## **Dimensions (mm/inch)**



### Modbus Map \_

The measured values are saved as a 32Bit float value from 0x2D to 0x30. The factory setting for the Slave-ID is 246 as an integer 16Bit value. This ID can be customised in the register 0x00 (permitted values 1 - 247).

#### FLOAT (read register):

#### INTEGER (write register):

Coil / Register Numbers	Data-Addresses	Parameter name	Coil / Register Numbers	Data-Addresses	Parameter name
30046	0x2D	$CO_2$ Response time = 60s	60001	0x00	Slave-ID
30048	0x2F	CO <sub>2</sub> Response time = 105s	60002	0x01	RS485 Setting
			60003	0x02	Measuring time interval

For Modbus protocol setting please see Application Note (www.epluse.com/EE871).

### **Operation outdoors**

**EE871** 

For outdoor applications EE871 must be used with the radiation shield order no. HA010507, which protects the device against rain, snow, ice, and solar radiation.



v2.0 / Modification rights reserved







......

## Scope of Supply \_

- EE871 probe according to ordering guide
- Test report according to DIN EN10204 2.2

### Ordering Guide \_\_\_\_\_

			EE871
Hardware		02000 ppm	HR2000
		05000 ppm	HR5000
	CO₂ Range	010,000 ppm	HR1
		03 % (only with E2 Interface)	HR3
		05 % (only with E2 Interface)	HR5
	Digital Output	E2 Interface	J2
		Modbus RTU	no code
Software <sup>1)</sup>		9600	no code
	Baudrate	19200	BD6
		38400	BD7
	Parity	no parity	PY0
		odd	no code
		even	PY2
	Stopbits	1 stopbit	no code
		2 stopbits	BT2

1) Only for Modbus RTU

## Ordering Example \_\_\_\_\_

## EE871-HR5J2

CO <sub>2</sub> ra	nge:
Digital	Output:

0...5 % E2 Interface

#### EE871-HR2000PY2BT2

CO <sub>2</sub> range:	02000 ppm
Digital Output:	Modbus RTU
Baudrate:	9600
Parity:	even
Stopbits:	2

### Accessories (For further information, see data sheet "Accessories")

Mounting flange M12x1 flanged coupling with 50mm (1,97") stranded wire	HA010212 HA010705
Modbus configuration adapter	HA011012
E2 lest and configuration adapter	HA011010
E+E Product configuration software	EE-PCS
(Download: www.epluse.com/Configurator)	
Connecting cable M12 - flying leads (1.5 m (59.06") / 5 m (196.85") / 10 m (393.70"))	HA0108 <b>19/20/21</b>
I-Coupler M12 - M12	HA030204
M12 Connector for self assembly	HA010707
PIFE filter cap	HA010116
Radiation shield	HA010507
Protection cap for the M12 cable socket	HA010781
Protection cap for the M12 plug of EE871	HA010782

#### Support Literature \_\_\_\_\_

www.epluse.com/EE871







